

A RESOLUTION AUTHORIZING AND DIRECTING THE MAYOR AND THE FINANCE DIRECTOR TO PURCHASE A REPLACEMENT GENERATOR FOR THE POLICE DEPARTMENT BUILDING FROM CUMMINS (SOURCEWELL CONTRACT NO. 092222-CMM); AND DECLARING AN EMERGENCY

WHEREAS, this Council desires to authorize the Mayor and Finance Director to purchase a replacement generator for the Police Department from Cummins in an amount not to exceed \$198,308.00, pursuant to the quote of Cummins, attached as Exhibit A (Sourcewell Contract No. 092222-CMM);

WHEREAS, the Generator will be ordered and purchased as part of the 2026 Capital Budget.

NOW, THEREFORE, BE IT RESOLVED by the Council of the Village of Richfield, County of Summit, State of Ohio that:

SECTION 1. The Mayor and Finance Director are hereby authorized to purchase one generator from Cummins in an amount not to exceed \$198,308.00 (Sourcewell Contract No. 092222-CMM) in accordance with the proposal attached hereto as Exhibit A.

SECTION 2. Because this purchase is made through a governmental cooperative purchasing program (Sourcewell), pursuant to Section 141.03(f)(7) of the Codified Ordinances of the Village of Richfield, Council hereby waives all competitive bidding requirements that ordinarily apply to such transactions.

SECTION 3. It is found and determined that all formal actions of this Council concerning and relating to the adoption of this Resolution were adopted in an open meeting of this Council, and that all deliberations of this Council and of any of its committees that resulted in such formal action, were in meetings open to the public, in compliance with all legal requirements including Section 121.22 of the Ohio Revised Code.

SECTION 4. This Resolution is hereby declared to be an emergency measure for the reason that it is immediately necessary to execute the purchase agreement; wherefore, this Resolution shall take immediate effect, provided that it receives the requisite number of votes needed to pass as an emergency measure; otherwise, it shall take effect at the earliest date allowed by law.

PASSED: 1/20/26




President of Council



Mayor

Dated: 1/20/2026

ATTEST:



Clerk of Council



November 7, 2025

Prepared by

Jeff Houlihan
 Senior Sales Executive - PG
 (440) 591-2331
 an135@cummins.com

We are pleased to provide this quotation based on your inquiry.

| Item | Description | Qty |
|------|---|-----|
| 1 | GTA855EICS, 383 HP, 8.5:1, Factory Certified for Emissions Catalyst, 5" Flange, NSPS 2/4/1 Duty Rating - Standby Power Listing - UL 2200 Natural Gas Enclosure - Galvaneal, , Base Mtd, Weather Protective with Exhaust System Onan Green Enclosure Color Generator - S4L1D-D41 (ADS #627), 60Hz, Winding 311 - 12 Wire, 120C, 0.8pf Voltage - 120/208, 3ph Exciter / Regulator - PMG, 3 Phase Sensor Set Control - Power Command 3.3 MLD Controls Facing Left Radiator Cooled Shutdown - Low Coolant Level Coolant Heater - 240V 1ph / 2500W Sightglass on Radiator Engine Governor - Electronic, Isochronous Only Engine Starter - 24 VDC Motor Battery Charging Alternator - Normal Output Engine Air Cleaner - Normal Duty Lube Oil, Engine Filled Prior to Shipment Anti-Freeze - 50/50 Mix, System Filled Prior to Shipment Critical Grade Silencer, Carbon Steel Extension - Oil Drain Extension - Engine Coolant Drain Bargraph - AC Analog Meters Manuals in English Battery Rack Battery Charger, 120 / 208 VAC Input, 10A / 24Vdc Output Fuel Strainer - Gaseous, 2in NPT Flexible Fuel Connection - Gaseous, 2in NPT Relays - Genset Status (User Configured) Switch - Emergency Stop, External Circuit Breaker - LSI_800A_80%, 600/525V Genset Warranty - Standby, 5 yr / 2500 hours parts, labor and travel Std CB Mounting Option Drip Rails | 1 |



| | | |
|---|--|---|
| 4 | 12VDC Engine Starting Battery - 700CCA | 1 |
| 5 | Service - start up & testing during normal working hours. | 1 |
| 6 | Service - load bank testing to verify proper fuel supply pressure and volume. | 1 |
| 7 | FOB first destination, unloading by others. | 1 |
| 8 | Remote E-stop - Pilla Part# GS120 w/ PILCLHCOV1, PILNCCB, and PILNOCB | 1 |
| 9 | OTECD, OTEC Transfer Switch-Electronic Control: 800A OTE800, Transfer Switch, PowerCommand, 800 Amp Listing - UL 1008/CSA Certification Application - Utility to Genset Cabinet - Type 1 Integral Control Power Supply Poles - 3 (Solid Neutral) Frequency - 60 Hz System - 3 Phase, 3 or 4 Wire Voltage - 208 Volts AC Genset Starting Battery - 12V DC PC40 Control Interface - Communication Network, MODBUS TCP Module Terminal Block - 30 Points Relay - Elevator Signal Auxiliary Contact Module-8 Transfer Switch Warranty - 5 Year Comprehensive | 1 |

TOTAL: \$198,308.00

Quote value does not include any tax.

OPTIONS:

1. Delete the transfer switch from the above proposal, re-using the existing ATS - deduct \$ 10,229.00 from base price.

EXCEPTIONS AND CLARIFICATIONS:

Proposal is for equipment only, offloading, rigging, and installation by others.

Fuel and permits, unless listed above, is not included.

Cummins Standard Start-up and testing is included. Additional tests, such as NETA testing, if required, is by others.

Coordination Study not provided.

No plans or specifications, quoted per customer request and site survey to replace the existing equipment due to age and obsolescence.

NOTES: