

A RESOLUTION AUTHORIZING THE SERVICE DIRECTOR TO CONDUCT EMERGENCY MAINTENANCE AND REPAIRS TO STATION NOS. 1, 3, 4 AND 5 OF THE VILLAGE'S SANITARY SEWER FACILITIES AND DECLARING AN EMERGENCY

WHEREAS, immediate maintenance and repairs to Station Nos. 1, 3, 4 and 5 of the Village's sanitary sewer system are immediately necessary; and

WHEREAS, this maintenance and repairs can be conducted during low flow periods which will eliminate the need for expensive construction of by-pass facilities; and

WHEREAS, the Service Director has received quotations for the maintenance and repair of Wet Well Nos. 1, 3, 4 and 5 which he believes are reasonable.

NOW, THEREFORE, BE IT RESOLVED by the Council of the Village of Richfield, State of Ohio, two-thirds of the members elected thereto concurring:

SECTION 1. That the Service Director be, and he hereby is, authorized and directed to conduct emergency maintenance and repairs to Wet Well Nos. 1, 3, 4 and 5 on an emergency basis without the necessity of formal bidding and advertisement in connection with the quotation sheet he received, a copy of which is attached hereto as Exhibit "A" and incorporated herein fully as if by reference.

SECTION 2. This Resolution is hereby declared to be an emergency measure necessary for the immediate preservation of the public health, safety and welfare and for the further reason that it is immediately necessary in order to have the maintenance and repairs conducted during the low flow period in order to eliminate by-pass construction and thereby save money for the Village; wherefore, provided this Resolution receives the affirmative vote of two-thirds of the members of Council elected or appointed, it shall take effect immediately upon its passage and execution by the Mayor; otherwise, it shall take effect and be in force from and after the earliest period allowed by law.

PASSED: September 7, 1999

Michael Lyons
President of Council

Donald W. Larsen
Mayor

ATTEST: Carole Gibson

Dated: 9/8/99

Clerk of Council

Pump Station Updates

Vendor	Barefoot & Case 5325-C Nainan Pkwy POBox 39546 Solon, Oh 44139	Dezurik 7325 Fair Oaks Rd. Cleveland, Oh 44146	G.A. Industry 9025 Marshall Rd. Mars, Pa 16046	Novatny 573 Kennedy Rd. Akron, Oh 44305	Kenmore Const. 700 Home Ave. Akron, Oh 44310	Kenmore Const. 700 Home Ave. Akron, Oh 44310	Kenmore Const. 700 Home Ave. Akron, Oh 44310	Total Cost Per Station
	Pump Assembly	Plug Valve	Check Valve	Complete Wiring	Install Discharge Valve	Pump Installation	Total	
Station #3	\$7,582.00	\$838.00	\$1,250.00	\$3,500.00	\$4,691.00	\$5,337.00	\$10,028.00	\$23,198.00
Station #4	\$10,980.00	\$838.00	\$1,250.00	\$4,000.00	\$4,691.00	\$7,587.00	\$12,278.00	\$29,346.00
Station #5	\$8,200.00	N/A	\$1,250.00	\$7,500.00	N/A	\$7,654.00	\$7,654.00	\$24,604.00
	\$26,762.00 ✓	\$1,676.00 ✓	\$3,750.00 ✓	\$15,000.00 ✓			\$29,960.00 ✓	\$77,148.00

Barefoot & Case
Kenmore Const.
Finkbeiner, Pettis & Strout

12 - 14 weeks for delivery
Prices good till 12-31-99
\$10,700.00 - needed if it goes to bid

Station #1 Wet Well Restoration Project

Lee Infrastructure
9058 S.R. 14
Streetsboro, Oh 44241

restoration \$26,872.00 ✓

Ohio Pressure Grouting *
3341 Cavalier Trail
Cuyahoga Falls, Oh 44224

restoration \$14,942.00

* Village supplies ventilation equipment
\$175.00 per cubic foot of additional material
Example: 75 extra cubic feet of shotcrete - \$19,317.00

BAREFOOT and CASE, INC.

MANUFACTURERS' REPRESENTATIVES

5325 - C Naiman Parkway

P.O. Box 39546

Solon, Ohio 44139

Phone: (440) 248 - 9777

Fax: (440) 248 - 9878

Date August 10, 1999

Proposal No. BC-081099-WB1

TO: Village of Richfield
4410 West Streetsboro
P.O. Box 387
Richfield, Ohio 44286

Attention: Mr. Dave Dietz

Subject: Pump Stations 3, 4 and 5

Gentlemen:

We are pleased to offer the following:

PUMP STATION NO. 3

One (1) 4" Fairbanks Morse Model B5443 Vertical Solids Handling Pump complete with dynamically balanced impeller, stainless steel wear rings, John Crane mechanical seal, suction discharge elbow with stand and (1) 15 H.P., TEFC, 1200 RPM, U.S. motor with coupling and guard.

Total cost, including delivery to jobsite \$7,582.00

PUMP STATION NO. 4

One (1) 4" Fairbanks Morse Model B5444 Vertical Solids Handling Pump complete with dynamically balanced impeller, stainless steel wear rings, John Crane mechanical seal, suction discharge elbow with stand and (1) 30 H.P., TEFC, 1200 RPM, U.S. motor with coupling and guard.

Total cost, including delivery to jobsite \$10,990.00

PUMP STATION NO. 5

One (1) 4" Fairbanks Morse Model B5443 Vertical Solids Handling Pump complete with dynamically balanced impeller, stainless steel wear rings, John Crane mechanical seal, suction discharge elbow with stand and (1) 50 H.P., TEFC, 1800 RPM, U.S. motor with coupling and guard.

Total cost, including delivery to jobsite \$8,200.00

Please note, all pumps shall be wound for 230/460 volts, 3 phase power.

NOT INCLUDED IN ABOVE QUOTATION: Installation, check valves, control panels, motor control centers or anything else other than specifically mentioned above.

- Continued on Page 2 -

TO: Village of Richfield
Attn: Mr. Dave Dietz
Subj: Pump Stations 3, 4 and 5

August 10, 1999
Page 2
BC-081099-WB1


DELIVERY: 12-14 weeks after receipt of order

TERMS: Net 30 days

We trust this gives you enough information to proceed. If you should require anything further, please kindly advise.

Very truly yours,

BAREFOOT & CASE, INC.
Manufacturers' Representatives



William P. Barefoot

WPB/mb